



2013 DEG 31 PM 4: 22

LISA D. NORDSTROM Lead Counsel Inordstrom@idahopower.com

December 31, 2013

Jean D. Jewell, Secretary Idaho Public Utilities Commission 472 West Washington Street P.O. Box 83720 Boise, Idaho 83720-0074

Re: Case No. IPC-E-07-02, Order No. 30274

Exemption from the Company's Rule C Provisions Regarding Aggregated Meter Reading

Dear Ms. Jewell:

Pursuant to Order No. 30274 in Case No. IPC-E-07-02, Idaho Power Company ("Company") hereby requests to add an additional customer to the list of customers exempt from Rule C's aggregated meter reading provisions. As outlined in the abbreviated procedure approved by the Idaho Public Utilities Commission ("Commission") in Order No. 30274, the Company is providing the customer's name, city location, and an explanation of why aggregation is appropriate for review prior to aggregating meter readings. The Commission envisioned that the Commission Staff would notify the Commission if it has an objection to the customer proposed for aggregation. (Order No. 30274, p.3.)

The Simplot facility in Caldwell was previously served from a single 28.5 MVA transformer, and the output of the transformer was metered with one meter serving multiple feeders dedicated to Simplot. In response to plans for increased load that will qualify for a Special Contract, Idaho Power installed an additional 28.5 MVA transformer at the dedicated substation. Because each transformer requires a separate meter to facilitate independent operation, which is the standard substation configuration, the optimal solution is to aggregate the meter readings.

If the Simplot facility in Caldwell is granted an exemption, the Company will submit an updated list of Customers exempt from Rule C's aggregated meter reading provisions.

If you have any questions regarding this request, please contact Connie Aschenbrenner at 388-5994 or caschenbrenner@idahopower.com.

Sincerely.

Lisa D. Nordstrom

LDN:kkt

cc: Greg Said
Brent Lulloff
Jake Perryman
Jim Hovda
RA File

Legal File